



अखिल भारतीय आयुर्वेद संस्थान, गोवा

ALL INDIA INSTITUTE OF AYURVEDA (AIIA), GOA

(आयुष मंत्रालय, भारत सरकार के अंतर्गत स्वायत्त संस्थान)

(An Autonomous Organization under the Ministry of AYUSH, Govt. of India)

File No- J-50/10/2026-AIIAGoa

Date: 11/08/2026

CORRIGENDUM

With reference to the Tender no. J-50/10/2026-AIIAGoa, dated 06/08/2026 for “Procurement, Supply, Installation, Testing and Commissioning (SITC) of Main LT Panel, LT Cabling, Earthing System and Associated Electrical Distribution Works for the CT Scan Machine and Other Associated Electrical Loads at AIIA Goa”, the following amendments are hereby made in Para No. 6 – Scope of Work / Technical Specifications, Section B – LT Cables & Terminations:

1. **B(1)(a):** Copper Conductor Cable shall be read as **Aluminium Conductor Cable**.
2. **B(2)(a):** Copper Conductor Cable shall be read as **Aluminium Conductor Cable**.

Sr. No.	Existing	Amendment
1	Supply & laying of 3.5 Core armored PVC insulated, PVC/XLPE sheathed copper conductor cable of 1.1 kV grade with ISI mark, conforming to IS 1554 (Part I) / IS 7098 (Part II), with latest amendments	Supply & laying of 3.5 Core armored PVC insulated, PVC/XLPE sheathed Aluminium conductor cable of 1.1 kV grade with ISI mark, conforming to IS 1554 (Part I) / IS 7098 (Part II), with latest amendments
a	3.5 Core × 300 sq. mm	3.5 Core × 300 sq. mm
2	Supplying and making cable end terminations with brass compression (double compression) glands and aluminum lugs for 3.5 Core PVC insulated, PVC sheathed/XLPE copper conductor cable of 1.1 kV grade, complete as required	Supplying and making cable end terminations with brass compression (double compression) glands and aluminum lugs for 3.5 Core PVC insulated, PVC sheathed/XLPE Aluminium conductor cable of 1.1 kV grade, complete as required
a	3.5 Core × 300 sq. mm	3.5 Core × 300 sq. mm

All other terms and conditions of the tender shall remain unchanged.

Dr. Sumeet Goel
In-charge,
Central Store, Goa

गांव - धारगल, तालुका - पेडणे, मनोहर अन्तर्राष्ट्रीय विमान पत्तन मार्ग, गोवा - 403513

Village-Dhargal, Taluka – Pernem, Manohar International Airport Road, Goa- 403513

Website: www.aiaa.org Email: goa-office@aiaa.gov.in Ph: +91 9311391886/ 8322918204 EXT 372